

CERTIFICATE

Number: 2125223.02



Issued to:
Applicant:
Giza Cable Industries
6 Ibn Malek st.
Giza, Egypt

Manufacturer/Licensee:
Giza Cable Industries
6 Ibn Malek st.
Giza, Egypt

Product : cables for rated voltage of 1 kV
Trade name : GIZA CABLE INDUSTRIES
Type/model : CU/XLPE/SWA/PVC

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA Quality hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60502-1:2004 / A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2114990

KEMA Quality hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 12 April 2010 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

H.R.M. Barends
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product	:	cables for rated voltage of 1 kV
trade name	:	GIZA CABLE INDUSTRIES
type	:	CU/XLPE/SWA/PVC
rated voltage	:	0.6/1 kV
type of conductors	:	copper
class of conductors	:	2
insulations	:	XLPE compound
inner covering	:	extruded PVC compound
armour	:	galvanized steel wires
oversheath	:	PVC compound, type ST 2
tested cables	:	4 x 1,5 mm ² and 4 x 300 mm ²
certified cables	:	1-5 x 1,5 mm ² up to and including 300 mm ²

TESTS

Test requirements

IEC 60502-1:2004 / A1:2009


Test result

The test results are laid down in KEMA Quality test file 2125223.02.

Conclusion

The examination proved that all test requirements were met.

Tested by : B. Vos



Checked by : A.A. Mackenbach

Factory location

Giza Cable Industries
6th October City, Giza
Egypt