

Certificate of Product Approval

Certificate Number: 1676c

Issue: 01

Giza Cable Industries

Fourth Industrial Zone
Plot 48
6th of October City
Giza Governorate
Egypt



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Cu/Mica/XLPE/AWA/LSHF cables

Standard(s) (see Appendix for details)

IEC 60331-21:1999
EN 60754-1:2014
EN 60754-2:2014
EN 61034-2:2005+A2:2020
EN 60332-3-24:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Al-eza

Signed for BRE Global Ltd.

Obada Piracha
Certification Manager

31 January 2022
Date of Issue

31 January 2022
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1676c Giza Cable Industries

Issue: 01

Product name		LPCB Ref. No.				
Cu/Mica/XLPE/AWA/LSHF		1676c/01				
Nominal csa of conductor (mm ²) See note 1	Core Construction	IEC 60331-21 See note 2	EN 60754-1	EN 60754-2	EN 61034-2	EN 60332-3-24
16	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
25	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
35	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
50	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
70	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
95	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
120	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
150	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
185	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
240	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
300	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
400	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aléer

Signed for BRE Global Ltd.

Obada Piracha
Certification Manager

31 January 2022
Date of Issue

31 January 2022
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1676c Giza Cable Industries

Issue: 01

Product name						LPCB Ref. No.
Cu/Mica/XLPE/AWA/LSHF						1676c/01
Nominal csa of conductor (mm2) See note 1	Core Construction	IEC 60331-21 See note 2	EN 60754-1	EN 60754-2	EN 61034-2	EN 60332-3-24
500	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
630	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies
800	One	(120 + 15) minutes	<0.5% HCl	Complies	>60%	Complies

Uo/U 600/1000V

Notes:

1. Stranded conductors only.
2. The Cu/Mica/XLPE/AWA/LSHF Cables met the requirements of IEC 60331-21:1999 when tested at a temperature of 750°C for a duration of 120 + 15 minutes cool down period, at a voltage rating of 600V.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Al-een
Signed for BRE Global Ltd.

Obada Piracha
Certification Manager

31 January 2022
Date of Issue

31 January 2022
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

