

## Certificate of Product Approval

Certificate Number: 1676b

Issue: 01

### Giza Cable Industries

Fourth Industrial Zone  
Plot 48  
6th of October City  
Giza Governorate  
Egypt



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
Cu/Mica/XLPE/LSHF cables

#### Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)  
IEC 60331-21:1999  
EN 61034-2:2005+A2:2020  
EN 60754-1:2014

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Piracha*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

19 January 2022  
Date of Issue

19 January 2022  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1676b Giza Cable Industries

Issue: 01

Product name					LPCB Ref. No.
Cu/Mica/XLPE/LSHF					1676b/01
Nominal csa of conductor (mm <sup>2</sup> ) See Note 1	Core Construction	BS 6387 See note 2 & 3	EN 60754-1	EN 61034-2	IEC 60331-21 See note 4
1.5	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
2.0	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
2.5	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
3.0	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
4.0	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
6.0	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
10	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
16	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
25	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
35	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
50	One	CWZ	<0.5% HCl	>60%	(120 + 15) minutes
70	One	C	<0.5% HCl	>60%	(120 + 15) minutes

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Al-een*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

19 January 2022  
Date of Issue

19 January 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1676b Giza Cable Industries

Issue: 01

Product name					LPCB Ref. No.
Cu/Mica/XLPE/LSHF					1676b/01
Nominal csa of conductor (mm <sup>2</sup> ) See Note 1	Core Construction	BS 6387 See note 2 & 3	EN 60754-1	EN 61034-2	IEC 60331-21 See note 4
95	One	C	<0.5% HCl	>60%	(120 + 15) minutes
120	One	C	<0.5% HCl	>60%	(120 + 15) minutes
150	One	C	<0.5% HCl	>60%	(120 + 15) minutes
185	One	C	<0.5% HCl	>60%	(120 + 15) minutes
240	One	C	<0.5% HCl	>60%	(120 + 15) minutes
300	One	C	<0.5% HCl	>60%	(120 + 15) minutes
400	One	C	<0.5% HCl	>60%	(120 + 15) minutes
500	One	-	<0.5% HCl	>60%	(120 + 15) minutes
630	One	-	<0.5% HCl	>60%	(120 + 15) minutes
800	One	-	<0.5% HCl	>60%	(120 + 15) minutes

**Uo/U 600/1000V**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Al-een*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

19 January 2022  
Date of Issue

19 January 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1676b Giza Cable Industries

Issue: 01

### Notes:

1. Stranded conductors only.
2. Where a single cable is tested in a conduit, only phase to earth voltage was applied.
3. When testing to BS 6387:2013, for Categories CWZ, testing was conducted using a 20mm or 38mm stainless steel conduit. Either one or three conductors are tested, and this is dependent on cable diameter. The conduit in all cases is connected to the neutral of the transformer.
4. The Cu/Mica/XLPE/LSHF Cables met the requirements of IEC 60331-21:1999 when tested at a temperature of 750°C for a duration of 120 + 15 minutes cool down period, at a voltage rating of 600V.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Aléer*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

19 January 2022  
Date of Issue

19 January 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.



**bre**